

Our Ref: HL/M1303111
Test Report: MAT/LAB 523G, 521G & 524G



16th January 2014

Miflex 2 Srl.
Strada Prov. Le 7 Per Lesmo No. 4,
20852 Villasanta (MB),
Italy

WATER REGULATIONS ADVISORY SCHEME (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS 6920-1:2000 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

HOSES & TUBING

5140

Miflex Type 103. Extruded, dual layer PVC hoses. The hoses have a black coloured inner layer and the outer layer is available in red, blue or grey. For use with water up to 60°C.

APPROVAL NUMBER: 1407504
APPROVAL HOLDER: MIFLEX 2 SRL.

This is a re-approval of 0906510 which is valid between June 2009 and June 2014.
The Scheme reserves the right to review approval.
Approval 1407504 is valid between July 2014 and July 2019.

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', is written over a light blue horizontal line.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme